

***Infonavit
HVAC Load Analysis***

for

Infonavit
Av. Juarez Manzana 44-a
Torreon Coahuila

Elite Software

CHVAC COMMERCIAL
HVAC LOADS

Prepared By:

Jamm
Alta Tecnologia

lunes, 19 de junio de 2017



General Project Data Input

General Project Information

Project file name: C:\Users\ALFRED\Desktop\ANTEPROYECTO A.A. INFONAVIT
 TORREON 160617\MEMORIA DE CALCULO\AREA DE
 ASESORES - 22.CHV

Project title: Infonavit
 Project address: AV.JUAREZ MANZANA 44-A
 Project city, state, ZIP: TORREON COAHUILA
 Designed by: Jamm
 Project date: Mayo 2017
 Weather reference city: TORREON, COAHUILA, MEXICO
 Client name: Infonavit
 Client address: Av. Juarez Manzana 44-a
 Client city: Torreon Coahuila
 Company name: Alta Tecnologia
 Company representative: Jamm

Barometric pressure: 29.921 in.Hg.
 Altitude: 0 feet
 Latitude: 25 Degrees
 Mean daily temperature range: 18 Degrees
 Starting & ending time for HVAC load calculations: 8am - 11pm
 Number of unique zones in this project: 1

Building Default Values

Calculations performed: Both heating and cooling loads

Lighting requirements: 2.00 Watts per square foot
 Equipment requirements: 2.00 Watts per square foot
 People sensible load multiplier: 250 Btuh per person
 People latent load multiplier: 250 Btuh per person
 Zone sensible safety factor: 5 %
 Zone latent safety factor: 5 %
 Zone heating safety factor: 5 %
 People diversity factor: 100 %
 Lighting profile number: 0
 Equipment profile number: 0
 People profile number: 0
 Building default ceiling height: 9.00 feet
 Building default wall height: 9.00 feet

Internal Operating Load Profiles (C = 100)

	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
1	C	C	C	C	C	C	C	C	C	C	70	70	70	C	C	C	C	C	C	C	C	C	C	C	C
2	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
3	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
4	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
5	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
6	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
7	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
8	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
9	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
10	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C



General Project Data Input (cont'd)

Building-Level Design Conditions

Design Month	Outdoor Dry Bulb	Outdoor Wet Bulb	Indoor Rel.Hum	Indoor Dry Bulb	Grains Diff	In/Outdoor Correction
August	95	73	50%	75	19.11	4
Winter	25			75		

Master Roofs

Roof No.	ASHRAE Roof#	Roof U-Fac	Dark Color	Susp. Ceil
1	13	0.260	No	No

Roof #1 Description: Flat roof, 4", 6" hollowcore panels deck with no insulation, suspended ceiling below with no insulation

Master Walls

Wall No.	ASHRAE Group	Wall U-Fac	Wall Color
1	E	0.046	L
2	G	0.062	L
3	G	0.032	L

Master Partitions

Partition No.	Partition U-Factor	Cool T-D	Heat T-D
1	0.196	25	25

Partition #1 Description: Block partition, 4" sand & gravel, hollow core, siding exterior, interior finish

Partition No.	Partition U-Factor	Cool T-D	Heat T-D
2	0.275	25	25

Partition #2 Description: Brick partition, 8" thick, face & common, interior finish

Master Glass

Glass No.	Summer U-Factor	Winter U-Factor	Glass Shd.Coef.	Interior Shading	Interior Shd.Coef
1	1.040	1.100	0.880	2	0.640

Master Shading Devices

Shade No.	Dist Horiz Overh Projects	Dist Beyond Right W.Edge	Dist Beyond Left W.Edge	Dist Overh Above Wind	Dist Right Fin Proj	Dist R-Fin Beyond W.Edge	Ht Of Right Fin	Dist Left Fin Proj	Dist L-Fin Beyond W.Edge	Ht Of Left Fin
1	2.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00
2	2.00	1.00	1.00	0.60	0.00	0.00	0.00	0.00	0.00	0.00



Building Summary Loads

Building peaks in August at 10pm.

Bldg Load Descriptions	Area Quan	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Roof	22,170	302,621	62.34	0	153,958	153,958	43.96
Wall	0	0	0.00	0	0	0	0.00
Glass	8	233	0.05	0	220	220	0.06
Floor Slab	0	0	0.00	0	0	0	0.00
Skin Loads		302,853	62.38	0	154,178	154,178	44.02
Lighting	500	0	0.00	0	1,791	1,791	0.51
Equipment	8,868	0	0.00	0	31,772	31,772	9.07
People	80	0	0.00	21,000	21,000	42,000	11.99
Partition	7,093	51,610	10.63	0	51,610	51,610	14.74
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	1,332	0	0.00	22,233	11,722	33,955	9.70
Heat. Vent.	1,332	71,932	14.82	0	0	0	0.00
Cool. Infil.	0	0	0.00	0	0	0	0.00
Heat. Infil.	0	0	0.00	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	13,976	13,976	3.99
Blow-Thru Fan	0	0	0.00	0	0	0	0.00
Reserve Cap.	0	0	0.00	0	0	0	0.00
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	39,385	8.11	0	14,438	14,438	4.12
Return Duct	0	19,692	4.06	0	6,487	6,487	1.85
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
Building Totals		485,473	100.00	43,233	306,975	350,208	100.00

Building Summary	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Ventilation	71,932	14.82	22,233	11,722	33,955	9.70
Infiltration	0	0.00	0	0	0	0.00
Pretreated Air	0	0.00	0	0	0	0.00
Zone Loads	354,464	73.01	21,000	260,352	281,352	80.34
Plenum Loads	0	0.00	0	0	0	0.00
Fan & Duct Loads	59,077	12.17	0	34,901	34,901	9.97
Building Totals	485,473	100.00	43,233	306,975	350,208	100.00

Check Figures

Total Building Supply Air (based on a 20° TD):	13,126 CFM
Total Building Vent. Air (10.15% of Supply):	1,332 CFM
Total Conditioned Air Space:	4,434 Sq.ft
Supply Air Per Unit Area:	2.9602 CFM/Sq.ft
Area Per Cooling Capacity:	151.9 Sq.ft/Ton
Cooling Capacity Per Area:	0.0066 Tons/Sq.ft
Heating Capacity Per Area:	109.49 Btuh/Sq.ft
Total Heating Required With Outside Air:	485,473 Btuh
Total Cooling Required With Outside Air:	29.18 Tons



Air Handler #1 - Area De Asesores - Summary Loads

Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
1	Area De Asesores 10pm August	4,434 80 39,906	354,464 18,234 4.11	260,352 13,126 2.96	21,000 0 0	10/P, 0.12/ft² 1,332 1,332	10/P, 0.12/ft² 1,332 1,332
Runout duct size: 6 in. dia, Diffusers: 146, CFM/runout: 125, Velocity: 636.1 ft/min, Pressure drop: 0.240 in.wg./100ft							
Zone Peak Totals:		4,434	354,464	260,352	21,000		
Total Zones: 1		80	18,234	13,126	0	1,332	1,332
Unique Zones: 1		39,906	4.11	2.96	0	1,332	1,332
Main trunk duct size: 56 in. h x 58in. w, Velocity: 869.7 ft/min, Pressure drop: 0.016 in.wg./100ft							



Air Handler #1 - Area De Asesores - Total Load Summary

Air Handler Description: Area De Asesores Constant Volume - Sum of Peaks
 Supply Air Fan: Draw-Thru with program estimated horsepower of 5.50 HP
 Fan Input: 75% motor and fan efficiency with 2 in. water across the fan
 Sensible Heat Ratio: 0.93 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 10pm in August.
 Outdoor Conditions: Clg: 83° DB, 70° WB, 87.51 grains, Htg: 25° DB
 Indoor Conditions: Clg: 75° DB, 50% RH, Htg: 75° DB

Summer: Ventilation controls outside air, ----- Winter: Ventilation controls outside air.

Zone Space sensible loss:	354,464 Btuh		
Infiltration sensible loss:	0 Btuh	0 CFM	
Outside Air sensible loss:	71,932 Btuh	1,332 CFM	
Supply Duct sensible loss:	39,385 Btuh		
Return Duct sensible loss:	19,692 Btuh		
Return Plenum sensible loss:	0 Btuh		
Total System sensible loss:			485,473 Btuh

Heating Supply Air: $393,848 / (1.000 \times 1.08 \times 20) =$		18,234 CFM	
Winter Vent Outside Air (7.3% of supply) =		1,332 CFM	

Zone space sensible gain:	260,352 Btuh		
Infiltration sensible gain:	0 Btuh		
Draw-thru fan sensible gain:	13,976 Btuh		
Supply duct sensible gain:	14,438 Btuh		
Reserve sensible gain:	0 Btuh		
Total sensible gain on supply side of coil:			288,766 Btuh

Cooling Supply Air: $288,766 / (1.000 \times 1.1 \times 20) =$		13,126 CFM	
Summer Vent Outside Air (10.1% of supply) =		1,332 CFM	

Return duct sensible gain:	6,487 Btuh		
Return plenum sensible gain:	0 Btuh		
Outside air sensible gain:	11,722 Btuh	1,332 CFM	
Blow-thru fan sensible gain:	0 Btuh		
Total sensible gain on return side of coil:			18,209 Btuh
Total sensible gain on air handling system:			306,975 Btuh

Zone space latent gain:	21,000 Btuh		
Infiltration latent gain:	0 Btuh		
Outside air latent gain:	22,233 Btuh		
Total latent gain on air handling system:			43,233 Btuh
Total system sensible and latent gain:			350,208 Btuh

Check Figures

Total Air Handler Supply Air (based on a 20° TD):		13,126 CFM	
Total Air Handler Vent. Air (10.15% of Supply):		1,332 CFM	
Total Conditioned Air Space:		4,434 Sq.ft	
Supply Air Per Unit Area:		2.9602 CFM/Sq.ft	
Area Per Cooling Capacity:		151.9 Sq.ft/Ton	
Cooling Capacity Per Area:		0.0066 Tons/Sq.ft	
Heating Capacity Per Area:		109.49 Btuh/Sq.ft	
Total Heating Required With Outside Air:		485,473 Btuh	
Total Cooling Required With Outside Air:		29.18 Tons	



Zone Detailed Loads (At Zone Peak Times)

Load Description	Unit Quan	-SC- CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
Zone 1-Area De Asesores peaks (sensible) in August at 10pm, Air Handler 1 (Area De Asesores), Group 0, 4,434.0 x 1.0, Construction Type: 1 (Light)								
Roof-1-13-No.Clg-L	22,170	0.50	25.4	0.260	146,627		13.000	288,210
Partition-1-2	7092.729		25/25	0.275	49,153		6.930	49,153
Gls-P-1-1-Tran	8.0	1.000	8	1.040	210		27.720	222
0%S-0-NS-Solar	8.0	0.880	0	0.000	0			
Lights-Prof=0	500	1.000			1,706			
Equipment-Prof=0	8,868	1.000			30,259	0		
People-Prof=1	80.0	1.000			20,000	20,000		
Sub-total					247,954	20,000		337,584
Safety factors:					+5%	+5%		+5%
Total w/ safety factors:					260,352	21,000		354,464



Air System #1 (Area De Asesores) Psychrometric Analysis (G)

System Load Analysis	Latent	Grains	Sensible	Temp	CFM
Leaving Coil Condition		62.275		55.000	
Draw-Thru Fan			13,976	0.968	635
Misc Load on Supply Side			0	0.000	0
Supply Air Duct			14,438	1.000	656
Zone Loads	21,000	2.353	260,352	18.032	11,834
Sensible Reserve			0	0.000	0
Zone Condition	21,000	64.627	288,766	75.000	13,126
Return Air Duct			6,487	0.500	
Return Air Plenum			0	0.000	
Misc Load on Return Side			0	0.000	
Vent Air 1,332 CFM	22,233	1.945	11,722	0.761	
Blow-Thru Fan			0	0.000	
Entering Coil Condition	43,233	66.573	306,975	76.261	13,126

General Psychrometric Equations Used In Analysis:

$PR = (\text{Barometric pressure of site} / \text{Standard ASHRAE pressure of } 29.921)$
 $TSH = PR \times 1.10 \times CFM \times (DB \text{ entering} - DB \text{ leaving})$
 $TLH = PR \times 0.68 \times CFM \times (\text{Grains entering} - \text{Grains leaving})$
 $GTH = PR \times 4.50 \times CFM \times (\text{Enthalpy entering} - \text{Enthalpy leaving})$

$TSH = 1.000 \times 1.10 \times 13,126 \times (76.261 - 55.000) = 306,975 \text{ Btuh}$
 $TLH = 1.000 \times 0.68 \times 13,126 \times (66.573 - 62.275) = 38,363 \text{ Btuh}$
 $SUM = 345,338 \text{ Btuh}$
 $GTH = 1.000 \times 4.50 \times 13,126 \times (28.717 - 22.858) = 346,069 \text{ Btuh}$
Total System Load = 350,208 Btuh

Chilled and Hot Water Flow Rates and Steam Requirement

$\text{Cooling GPM} = 346,069 / (0.00 \times 500) = 0.0 \text{ GPM}$
 $\text{Heating GPM} = 485,473 / (0.00 \times 500) = 0.0 \text{ GPM}$
 $\text{Steam Req.} = 485,473 / 970 = 500.5 \text{ lb./hr}$

Entering Cooling Coil Conditions

Dry bulb temperature: 76.26
 Wet bulb temperature: 63.40
 Relative humidity: 49.36
 Enthalpy: 28.72 Btu/lbm

Entering Heating Coil Conditions

Dry bulb temperature: 70.42

Leaving Cooling Coil Conditions

Dry bulb temperature: 55.00
 Wet bulb temperature: 54.47
 Relative humidity: 96.80
 Enthalpy: 22.86 Btu/lbm


Leaving Heating Coil Conditions

Dry bulb temperature: 95.00



Air System #1 (Area De Asesores) Psychrometric Chart

ZC	Zone Condition	OC	Outdoor Condition
LC	Leaving Coil Condition	EC	Entering Coil Condition
SD	Supply Duct Temperature Rise	RD	Return Duct Temperature Rise
DTF	Draw Through Fan Sensible Gain	BTF	Blow Through Fan Sensible Gain
RE	Reserve or Reheat Sensible Gain	PL	Return Air Plenum Sensible Gain
SM	Supply Side Miscellaneous Sensible Gain	RM	Return Side Miscellaneous Gain
PRE	Pretreated Air Condition	HRV	Heat Recovery Ventilator Condition





Air System #1 (Area De Asesores) Psychrometric Chart (G)

ZC	Zone Condition	OC	Outdoor Condition
LC	Leaving Coil Condition	EC	Entering Coil Condition
SD	Supply Duct Temperature Rise	RD	Return Duct Temperature Rise
DTF	Draw Through Fan Sensible Gain	BTF	Blow Through Fan Sensible Gain
RE	Reserve or Reheat Sensible Gain	PL	Return Air Plenum Sensible Gain
SM	Supply Side Miscellaneous Sensible Gain	RM	Return Side Miscellaneous Gain
PRE	Pretreated Air Condition	HRV	Heat Recovery Ventilator Condition

