

Infonavit
HVAC Load Analysis

for

Infonavit
AV. JUAREZ MANZANA 44-A
TORREON COAHUILA

Elite Software

CHVAC COMMERCIAL
HVAC LOADS

Prepared By:

Jamm
Alta Tecnologia

lunes, 19 de junio de 2017



General Project Data Input

General Project Information

Project file name: C:\Users\ALFRED\Desktop\ANTEPROYECTO A.A. INFONAVIT TORREON 160617\MEMORIA DE CALCULO\SALA DE JUNTAS - 22.CHV

Project title: Infonavit

Project address: AV.JUAREZ MANZANA 44-A

Project city, state, ZIP: TORREON COAHUILA

Designed by: Jamm

Project date: Mayo 2017

Weather reference city: TORREON, COAHUILA, MEXICO

Client name: Infonavit

Client address: AV.JUAREZ MANZANA 44-A

Client city: TORREON COAHUILA

Company name: Alta Tecnologia

Company representative: Jamm

Barometric pressure: 29.921 in.Hg.

Altitude: 0 feet

Latitude: 25 Degrees

Mean daily temperature range: 18 Degrees

Starting & ending time for HVAC load calculations: 8am - 11pm

Number of unique zones in this project: 1

Building Default Values

Calculations performed: Both heating and cooling loads

Lighting requirements: 2.00 Watts per square foot

Equipment requirements: 2.00 Watts per square foot

People sensible load multiplier: 250 Btuh per person

People latent load multiplier: 250 Btuh per person

Zone sensible safety factor: 5 %

Zone latent safety factor: 5 %

Zone heating safety factor: 5 %

People diversity factor: 100 %

Lighting profile number: 0

Equipment profile number: 0

People profile number: 0

Building default ceiling height: 9.00 feet

Building default wall height: 9.00 feet

Internal Operating Load Profiles (C = 100)

	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	C	C	C	C	C	C	C	C	C	C	70	70	70	C	C	C	C	C	C	C	C	C	C	C
2	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
3	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
4	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
5	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
6	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
7	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
8	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
9	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
10	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C



General Project Data Input (cont'd)

Building-Level Design Conditions

Design Month	Outdoor Dry Bulb	Outdoor Wet Bulb	Indoor Rel.Hum	Indoor Dry Bulb	Grains Diff	In/Outdoor Correction
August	95	73	50%	75	19.11	4
Winter	25			75		

Master Roofs

Roof No.	ASHRAE Roof#	Roof U-Fac	Dark Color	Susp. Ceil
1	9	0.320	Si	Si

Roof #1 Description: Flat roof, 2" heavy weight concrete deck with no insulation, suspended ceiling below with no insulation

Master Walls

Wall No.	ASHRAE Group	Wall U-Fac	Wall Color
1	E	0.046	D
2	G	0.062	L
3	G	0.032	L

Master Partitions

Partition No.	Partition U-Factor	Cool T-D	Heat T-D
1	0.196	25	25

Partition #1 Description: Block partition, 4" sand & gravel, hollow core, siding exterior, interior finish

Partition No.	Partition U-Factor	Cool T-D	Heat T-D
2	0.275	25	25

Partition #2 Description: Brick partition, 8" thick, face & common, interior finish

Master Glass

Glass No.	Summer U-Factor	Winter U-Factor	Glass Shd.Coef.	Interior Shading	Interior Shd.Coef
1	1.040	1.100	0.880	2	0.640

Master Shading Devices

Shade No.	Dist Horiz Overh Projects	Dist Beyond Right W.Edge	Dist Beyond Left W.Edge	Dist Overh Above Wind	Dist Right Fin Proj	Dist R-Fin Beyond W.Edge	Ht Of Right Fin	Dist Left Fin Proj	Dist L-Fin Beyond W.Edge	Ht Of Left Fin
1	2.00	0.00	0.00	0.60	0.00	0.00	0.00	0.00	0.00	0.00
2	2.00	1.00	1.00	0.60	0.00	0.00	0.00	0.00	0.00	0.00

**Building Summary Loads**

Building peaks in August at 6pm.

Bldg Load Descriptions	Area Quan	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Roof	644	10,813	37.15	0	9,056	9,056	30.49
Wall	0	0	0.00	0	0	0	0.00
Glass	8	233	0.80	0	220	220	0.74
Floor Slab	0	0	0.00	0	0	0	0.00
Skin Loads		11,046	37.95	0	9,276	9,276	31.23
Lighting	80	0	0.00	0	287	287	0.96
Equipment	805	0	0.00	0	2,882	2,882	9.70
People	10	0	0.00	2,625	2,625	5,250	17.67
Partition	127	924	3.17	0	924	924	3.11
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	280	0	0.00	4,334	4,936	9,270	31.21
Heat. Vent.	280	15,144	52.03	0	0	0	0.00
Cool. Infil.	0	0	0.00	0	0	0	0.00
Heat. Infil.	0	0	0.00	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	773	773	2.60
Blow-Thru Fan	0	0	0.00	0	0	0	0.00
Reserve Cap.	0	0	0.00	0	0	0	0.00
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	1,330	4.57	0	798	798	2.69
Return Duct	0	665	2.28	0	245	245	0.82
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
Building Totals		29,109	100.00	6,959	22,746	29,705	100.00

Building Summary	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Ventilation	15,144	52.03	4,334	4,936	9,270	31.21
Infiltration	0	0.00	0	0	0	0.00
Pretreated Air	0	0.00	0	0	0	0.00
Zone Loads	11,970	41.12	2,625	15,994	18,619	62.68
Plenum Loads	0	0.00	0	0	0	0.00
Fan & Duct Loads	1,995	6.85	0	1,816	1,816	6.11
Building Totals	29,109	100.00	6,959	22,746	29,705	100.00

Check Figures

Total Building Supply Air (based on a 22° TD): 726 CFM
Total Building Vent. Air (38.64% of Supply): 280 CFM

Total Conditioned Air Space: 402 Sq.ft
Supply Air Per Unit Area: 1.8043 CFM/Sq.ft
Area Per Cooling Capacity: 162.5 Sq.ft/Ton
Cooling Capacity Per Area: 0.0062 Tons/Sq.ft
Heating Capacity Per Area: 72.36 Btuh/Sq.ft

Total Heating Required With Outside Air: 29,109 Btuh
Total Cooling Required With Outside Air: 2.48 Tons



Air Handler #1 - Sala De Juntas - Summary Loads

Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
1	Sala Dejuntas 8pm August	402 10 3,620	11,970 616 1.53	15,994 726 1.80	2,625 0 0	20/P, 0.2/ft ² 280 280	20/P, 0.2/ft ² 280 280
Runout duct size: 6 in. dia, Diffusers: 6, CFM/runout: 121, Velocity: 616.1 ft/min, Pressure drop: 0.243 in.wg./100ft							
Zone Peak Totals:		402	11,970	15,994	2,625		
Total Zones: 1		10	616	726	0	280	280
Unique Zones: 1		3,620	1.53	1.80	0	280	280
Main trunk duct size: 14 in. h x 12in. w, Velocity: 678.9 ft/min, Pressure drop: 0.068 in.wg./100ft							



Air Handler #1 - Sala De Juntas - Total Load Summary

Air Handler Description: Sala De Juntas Constant Volume - Sum of Peaks
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.30 HP
 Fan Input: 75% motor and fan efficiency with 2 in. water across the fan
 Sensible Heat Ratio: 0.87 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 6pm in August.
 Outdoor Conditions: Clg: 91° DB, 72° WB, 84.75 grains, Htg: 25° DB
 Indoor Conditions: Clg: 75° DB, 50% RH, Htg: 75° DB

Because of the diversity in zone, plenum and ventilation loads, the zone sensible peak time in August at 8pm is different from the total system peak time, hence the air system CFM was computed using a zone sensible load of 15,994.

Summer: Ventilation controls outside air, ----- Winter: Ventilation controls outside air.

Zone Space sensible loss:	11,970 Btuh		
Infiltration sensible loss:	0 Btuh	0 CFM	
Outside Air sensible loss:	15,144 Btuh	280 CFM	
Supply Duct sensible loss:	1,330 Btuh		
Return Duct sensible loss:	665 Btuh		
Return Plenum sensible loss:	0 Btuh		
Total System sensible loss:			29,109 Btuh
Heating Supply Air: $13,300 / (1.000 \times 1.08 \times 20) =$		616 CFM	
Winter Vent Outside Air (45.5% of supply) =		280 CFM	
Zone space sensible gain:	15,994 Btuh		
Infiltration sensible gain:	0 Btuh		
Draw-thru fan sensible gain:	773 Btuh		
Supply duct sensible gain:	798 Btuh		
Reserve sensible gain:	0 Btuh		
Total sensible gain on supply side of coil:			17,565 Btuh
Cooling Supply Air: $17,565 / (1.000 \times 1.1 \times 22) =$		726 CFM	
Summer Vent Outside Air (38.6% of supply) =		280 CFM	
Return duct sensible gain:	245 Btuh		
Return plenum sensible gain:	0 Btuh		
Outside air sensible gain:	4,936 Btuh	280 CFM	
Blow-thru fan sensible gain:	0 Btuh		
Total sensible gain on return side of coil:			5,181 Btuh
Total sensible gain on air handling system:			22,746 Btuh
Zone space latent gain:	2,625 Btuh		
Infiltration latent gain:	0 Btuh		
Outside air latent gain:	4,334 Btuh		
Total latent gain on air handling system:			6,959 Btuh
Total system sensible and latent gain:			29,705 Btuh

Check Figures

Total Air Handler Supply Air (based on a 22° TD):	726 CFM
Total Air Handler Vent. Air (38.64% of Supply):	280 CFM
Total Conditioned Air Space:	402 Sq.ft
Supply Air Per Unit Area:	1.8043 CFM/Sq.ft
Area Per Cooling Capacity:	162.5 Sq.ft/Ton
Cooling Capacity Per Area:	0.0062 Tons/Sq.ft
Heating Capacity Per Area:	72.36 Btuh/Sq.ft
Total Heating Required With Outside Air:	29,109 Btuh
Total Cooling Required With Outside Air:	2.48 Tons



Zone Detailed Loads (At Zone Peak Times)

Load Description	Unit Quan	-SC- CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
Zone 1-Sala Dejuntas peaks (sensible) in August at 8pm, Air Handler 1 (Sala De Juntas), Group 0, 402.3 x 1.0, Construction Type: 1 (Light)								
Roof-1-9-Susp.C-D	644	1.00	41.9	0.320	8,624		16.000	10,298
Partition-1-2	127		25/25	0.275	880		6.930	880
Gls-P-1-1-Tran	8.0	1.000	12	1.040	210		27.720	222
0%S-0-NS-Solar	8.0	0.880	0	0.000	0			
Lights-Prof=0	80	1.000			273			
Equipment-Prof=0	805	1.000			2,745	0		
People-Prof=1	10.0	1.000			2,500	2,500		
Sub-total					15,232	2,500		11,400
Safety factors:					+5%	+5%		+5%
Total w/ safety factors:					15,994	2,625		11,970



Air System #1 (Sala De Juntas) Psychrometric Analysis (G)

System Load Analysis	Latent	Grains	Sensible	Temp	CFM
Leaving Coil Condition		59.322		53.000	
Draw-Thru Fan			773	0.968	32
Misc Load on Supply Side			0	0.000	0
Supply Air Duct			798	1.000	33
Zone Loads	2,625	5.319	15,994	20.033	661
Sensible Reserve			0	0.000	0
Zone Condition	2,625	64.641	17,565	75.000	726
Return Air Duct			245	0.500	
Return Air Plenum			0	0.000	
Misc Load on Return Side			0	0.000	
Vent Air 280 CFM	4,334	6.610	4,936	5.989	
Blow-Thru Fan			0	0.000	
Entering Coil Condition	6,959	71.251	22,746	81.489	726

General Psychrometric Equations Used In Analysis:

$PR = (\text{Barometric pressure of site} / \text{Standard ASHRAE pressure of } 29.921)$
 $TSH = PR \times 1.10 \times CFM \times (DB \text{ entering} - DB \text{ leaving})$
 $TLH = PR \times 0.68 \times CFM \times (\text{Grains entering} - \text{Grains leaving})$
 $GTH = PR \times 4.50 \times CFM \times (\text{Enthalpy entering} - \text{Enthalpy leaving})$

$TSH = 1.000 \times 1.10 \times 726 \times (81.489 - 53.000) = 22,745 \text{ Btuh}$
 $TLH = 1.000 \times 0.68 \times 726 \times (71.251 - 59.322) = 5,887 \text{ Btuh}$
 $SUM = 28,632 \text{ Btuh}$
 $GTH = 1.000 \times 4.50 \times 726 \times (30.727 - 21.913) = 28,789 \text{ Btuh}$
 Total System Load = 29,705 Btuh

Chilled and Hot Water Flow Rates and Steam Requirement

Cooling GPM = $28,789 / (0.00 \times 500) = 0.0 \text{ GPM}$
 Heating GPM = $29,109 / (0.00 \times 500) = 0.0 \text{ GPM}$
 Steam Req. = $29,109 / 970 = 30.0 \text{ lb./hr}$

Entering Cooling Coil Conditions

Dry bulb temperature: 81.49
 Wet bulb temperature: 66.09
 Relative humidity: 44.44
 Enthalpy: 30.73 Btu/lbm

Entering Heating Coil Conditions

Dry bulb temperature: 51.68

Leaving Cooling Coil Conditions

Dry bulb temperature: 53.00
 Wet bulb temperature: 52.89
 Relative humidity: 99.28
 Enthalpy: 21.91 Btu/lbm


Leaving Heating Coil Conditions

Dry bulb temperature: 95.00



Air System #1 (Sala De Juntas) Psychrometric Chart

ZC	Zone Condition	OC	Outdoor Condition
LC	Leaving Coil Condition	EC	Entering Coil Condition
SD	Supply Duct Temperature Rise	RD	Return Duct Temperature Rise
DTF	Draw Through Fan Sensible Gain	BTF	Blow Through Fan Sensible Gain
RE	Reserve or Reheat Sensible Gain	PL	Return Air Plenum Sensible Gain
SM	Supply Side Miscellaneous Sensible Gain	RM	Return Side Miscellaneous Gain
PRE	Pretreated Air Condition	HRV	Heat Recovery Ventilator Condition





Air System #1 (Sala De Juntas) Psychrometric Chart (G)

ZC	Zone Condition	OC	Outdoor Condition
LC	Leaving Coil Condition	EC	Entering Coil Condition
SD	Supply Duct Temperature Rise	RD	Return Duct Temperature Rise
DTF	Draw Through Fan Sensible Gain	BTF	Blow Through Fan Sensible Gain
RE	Reserve or Reheat Sensible Gain	PL	Return Air Plenum Sensible Gain
SM	Supply Side Miscellaneous Sensible Gain	RM	Return Side Miscellaneous Gain
PRE	Pretreated Air Condition	HRV	Heat Recovery Ventilator Condition

